

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20150313-MH20491  
**Report Reference** MH16166-19920505  
**Issue Date** 2015-MARCH-13

**Issued to:** PADUNGSILPA ENGINEERING CO LTD  
16/77 SOI CHANGWATTANA 14  
CHANGWATTANA RD  
TUNG SONG HONG, LAKSI  
BANGKOK 10210 THAILAND

**This is to certify that  
representative samples of**

UNDERGROUND FLAMMABLE LIQUID TANKS  
"ACT-100" Single wall, Type I and Type II secondary  
containment composite underground tanks for flammable  
liquids.


Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 1746, Safety for External Corrosion Protection Systems  
for Steel Underground Storage Tanks.  
UL 58, Steel Underground Tanks for Flammable and  
Combustible Liquids.

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

